



Assistant Municipal Commissioner
Nagar Road Wadgaonsheri Ward
Office

Outward No : 11301 Date : 13/03/2024


CERTIFICATE REGARDING

SANITARY CONDITION CERTIFICATE

It is certified that an inspection team headed by Mr. Hanumanta Savali - Divisional Sanitary Inspector, (Name of the officers with designation) From - Nagarroad Ward Office PMC, Pune -411014. (Name of the Department / Office) Inspected on Date : 04/03/2024 "Mount Litera Zee School" Gat No.866/1/2/3, Wagholi, Avhalwadi, Kesnand Road, Pune -412207

Has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building and the campus as per the norms prescribed by the Central /State /Union Territory Government.

The above valid for a period up to Date : 31/03/2025


(Mr. Hanumanta Savali)

Divisional Sanitary Inspector
Nagarroad-Wadgaonsheri Ward Office
Pune Municipal Corporation

To
Principal
Mount Litera Zee School
Gat No.866/1/2/3, Wagholi,
Avhalwadi, Kesnand Road, Pune -412207



PUNE MUNICIPAL CORPORATION

Parvati Water Works Laboratory

Report of Water Samples Collected as on 17/01/2024

Challan No : 12423000008

Challan Date : 17/01/2024

Amount (Rs.): 1620.0

Date : 20/01/2024

Report ID : CH3

पुणे महानगरपालिका
पर्वती जलकेंद्र पुणे ३०.
जावक क्र.- CH-3
दिनांक- 20/01/2024

मालकाचे नाव : Mount Litera Zee School, Wagholi


1) Mount Litera Zee School, Wagholi-Pune, Ganga Hilshire, GAT 886/1 , Kesnand Road, Wagholi, Pune-412207,
Purifier Water Sample

As per I.S Standard No. 10500:2012				
Parameter	Results	Desirable Limit	Permissible Limit	Unit
PH	7.32	Between 6.5 To 8.5	No Relaxation	-
Turbidity	1.0	Max 1	Max 5	N.T.U
Total Hardness (as CaCO ₃)	29.0	Max 200	Max 600	PPM
Chlorides (as Cl)	16.0	Max 250	Max 1000	PPM
Alkanity (as calcium carbonate)	32.0	Max 200	Max 600	PPM
Nitrate Nitrogen (as NO ₃)	0.1	Max 45	No relaxation	PPM
Nitrite Nitrogen (as NO ₂)	0.03	-	-	PPM
Coliform	0	0	0	100ml
E-Coli	0	0	0	100ml
Residual Chlorine Test	2.0	0.2	-	PPM

Remark : सदरचा नमुना / नमुने मालकांनी स्वतः आणून दिला. उपरोक्त नमुना / नमुने हा प्रातिनिधिक असल्याचे गृहीत धरले आहे. सदरचा अहवाल हा वैयक्तिक माहितीसाठी असून, याचा वापर कुठल्याही प्रकारचा परवान्यासाठी केल्याने उद्भवणाऱ्या कायदेशीर बाबींस हे कार्यालय जबाबदार असणार नाही. तसेच नमुनांच्या उद्दगमाविषयीचा पडताळा ह्या कार्यालयामार्फत केलेला नाही.

शेरा :

The Above Water Sample Is Potable as per IS:10500:2012


20/01/2024
कमिस्ट
पर्वती जलकेंद्र
पुणे महानगरपालिका

पुणे महानगरपालिका

Demand Note No : WS20240117-12423-000008

खात्याचे नाव : पर्वती जलकेंद्र


मालकाचे नाव : MOUNT LITERA ZEE SCHOOL

पत्ता : GANGA HILLSHIRE GAT 886/1, KESNAND
ROAD, WAGHOLI PUNE 412207

टिप्पणी : WATER TESTING CHARGES (1 PURIFIER
WATER SAMPLE * RS. 1620/-)

कामाचा तपशील :	रक्कम :
ड.खाजगी कामासाठी - XI12E101	1620
एकूण	1620

एकूण रक्कम रु : ONE THOUSAND SIX HUNDRED
TWENTY ONLY


17/01/2024

खातेप्रमुख,
पर्वती जलकेंद्र

पुणे महानगरपालिका

वरीलप्रमाणे रोख/चेक/मनिऑर्डरने मिळाले.

पैसे मिळाल्याचा
बँकेचा शिक्का



स्वाक्षरी

दिनांक 17/01/2024, 12:01, PM